



कार्यालय सिविल सर्जन  
करनाल-132001

फोन नं. 0184-2267796, 2267569 ईमेल: dhs.esknlw@ry.nic.in



NO OBJECTION CERTIFICATE

Certify that the premises of Monfort World School, Airport Road, Kunjpura Karnal has been inspected on dated 14.02.2025. The campus of the Institute has been found satisfactory from Sanitation & Hygiene point of view. This certificate is valid for one year from the date of issue.

Dy. Civil Surgeon (School Health)  
Karnal

No. SHC/KNL/2025/246

Date: 25/2/2025

A Copy is forwarded to the Monfort World School, Airport Road, Kunjpura Karnal for information.

Dy. Civil Surgeon (School Health)  
Karnal

  
Manager  
Montfort World School  
Kunjpura (Karnal)

  
Principal  
Montfort World School  
Kunjpura (Karnal)





Memo No:- 605

Date:- 29/01/2025

Certificate  
No: TC-13659

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : KNL/13058/1/2025 / Private			Sample Details		Date & Time	
Sender : Principal Montfort World School			Collected By		STAFF	
Location : , Airport Road,Kunjpura ,Karnal			Collection Date		28/01/2025 at 15:22	
			Received at lab		28/01/2025 at 15:26	
Sample Description : Drinking Water			Analysis Start Date		28/01/2025	
Latitude / Longitude : 76.979836 / 29.688164			Analysis End Date		29/01/2025	
			Sample Quantity		1000ML	
Test Result (As Per BIS 10500 :2012)						
S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used	
1	Turbidity	<1	1 NTU	5 NTU	IS 3025 (Part-10):1984 (RA 2022)	
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) :1984 (RA 2022)	
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) :1984 (RA 2018)	
4	Color	<5	5 Hazen Units	15 Hazen Units	IS 3025 (Part 4): 2021	
5	Total Dissolved Solids @ 180°c ± 2°c	150	500 mg/lt.	2000 mg/lt.	IS 3025 (Part-16) : 2023	
6	Total Hardness as CaCo3	100	200 mg/lt.	600 mg/lt.	IS 3025 (Part-21) : 2009 (RA 2023)	
7	Calcium as Ca	20	75 mg/lt.	200 mg/lt.	IS 3025 (Part-40) :1991 (RA 2023)	
8	Magnesium as Mg	24	30 mg/lt.	100 mg/lt.	IS 3025 (Part-46) (RA 2023)	
9	Total Alkalinity	120	200 mg/lt.	600 mg/lt.	IS 3025 (Part-23) : 1986 (RA 2019)	
10	Chloride as Cl	36	250 mg/lt.	1000 mg/lt.	IS 3025 (Part-32) :1988 (RA 2019)	
11	Sulphate as So4	20	200 mg/lt.	400 mg/lt.	USEPA-8051:2017	
12	Fluoride as F	0.40	1.0 mg/lt.	1.5 mg/lt.	APHA 24th Edition-4500F C	
13	Iron as Fe	0.01	1.0 mg/lt.	1.0 mg/lt.	USEPA-8008:2017	
14	Nitrate as No3	2.4	45 mg/lt.	45 mg/lt.	APHA 24th Edition -4500 NO3 D	
15	pH @ 25°c	7.32	6.5 - 8.5	6.5 - 8.5	IS 3025 (Part-11) : 2022	

Remarks :-

- \* The Results Given above are related to the sample as received and tested in PHED KARNAL Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by  
*Joinder Singh*

*Amit Kumar*  
AMIT KUMAR, CHIEF CHEMIST 29/01/25  
STATE WATER TESTING LABORATORY, KARNAL  
email:-chiefchemist\_hr@phedharyana.gov.in

*[Signature]*  
**Manager**  
**Montfort World School**  
**Kunjpura (Karnal)**

*[Signature]*  
**Principal**  
**Montfort World School**  
**Kunjpura (Karnal)**